



EC-Conformity Declaration

For the following equipment :

Switching Power Supply

(Product Name)

GSWxy (w=18, 25; x=A, B, E; y=03, 05, 07, 09, 12, 15, 18, 24, 28, 48)

(Model Designation)

is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied :

Low Voltage Directive (73/23/EEC, 93/68/EEC) :

EN60950-1:2001 GSWAy TUV certificate No:TA50092395

GSWB/Ey TUV certificate No:TA50092324

Electromagnetic Compatibility (89/336/EEC) :

Emission Measurement Standard

Conducted emissions	EN61204-3, EN55011, EN55022, EN61000-6-3	Class B
Radiated emissions	EN61204-3, EN55011, EN55022, EN61000-6-3	Class B

Immunity Measurement Basic Standard (EN 55024, EN 61204-3 and en61000-6-1)

Harmonic distortion	EN61000-3-2	Conforms
Voltage flicker	EN61000-3-3	Conforms
ESD air	EN61000-4-2	Level 3 8KV
ESD contact	EN61000-4-2	Level 2 4KV
RF field susceptibility	EN61000-4-3	Level 2 3V/m
	EN 50204	
EFT bursts	EN61000-4-4	Level 2 1KV/5KHz
Surge susceptibility	EN61000-4-5	Level 3 1KV/Line-Line
		Level 3 2KV/Line-Earth
Conducted susceptibility	EN61000-4-6	Level 2 3V
Magnetic field immunity	EN61000-4-8	Level 1 1A/m
	EN61000-6-1	Level 2 3A/m
Voltage dip, interruption	EN61000-4-11	Conforms 30% dip 10mS
		60% dip 100mS
		>95% interruptions 5S

Component power supply will be installed into a final equipment. Since EMC performance will be effected by complete installation, the final equipment manufacturers must re-conform EMC Directive on final equipment again.

Person responsible for marking this declaration :

Mean Well Enterprises Co., Ltd.

(Company Name)

No.28, Wu-Chuan 3rd Road, Wu Ku Ind. Park, Taipei Hsien, Taiwan

(Company Address)

Roger Lai.

(Name, Surname)

Taiwan


(Place)

Sep.11.2007

(Date)

Manager

(Position/Title)


(Legal Signature)